



West Control Solutions
The Hyde Business Park,
Brighton BN2 4JU, UK

Web: www.west-cs.com
e-mail: info@west-cs.com
Tel: +44 (0) 1273 606271
Fax: +44 (0) 1273 609990

DECLARATION OF CONFORMITY

ET241 Series

This product is manufactured at the premises of West Control Solutions, The Hyde Business Park, Brighton, East Sussex, BN2 4JU, England, UK

This declaration of conformity is issued under the sole responsibility of the manufacturer.

The objects of this declaration are the products identified using the model numbers derived from the tables listed below.

The objects of this declaration are in conformity with the following European Union harmonisation legislation:

2014/30/EU Electromagnetic Compatibility

2014/35/EU Low Voltage Directive

2011/65/EU Restriction of Hazardous Substances in Electrical and Electronic Equipment

The assessment of conformity has been made using the standards route to compliance. The standards this product is compliant with are listed below: -

EN 61326-1:2013 Electrical equipment for measurement, control and laboratory use — EMC Requirements — Part 1: General Requirements


This product has been evaluated as Class A equipment suitable for operation in Industrial Locations against this standard.

WARNING

This is a Class A product. In a domestic environment this product may cause radio interference in which case the user may be required to take adequate measures.

EN 61010-1:2010, Safety requirements for electrical equipment for measurement, control and laboratory use.

This declaration is made for and on behalf of Fortive by Stephan Sommer, who has been designated as the responsible person for the purpose of the regulations.

Signature: 
(S. Sommer)

Date of Issue: 20/07/2016

Order Code	ET241	-	X	-	XXX	-	XX
Number of relays outputs							
1			1				
2			2				
Power supply input							
230VAC					230		
24V AC/DC					24		
12V AC/DC					12		
9 - 30VDC / 7-24VAC					SM		
Power Relay Option							
5A relay*							05*
8A relay							08
16A relay*							16*
*Only available in ET2411							